

# RECALL SAFETY NOTICE

## Risk: Fire Hazard

Potential damage from overheating and fire to appliances or other equipment



## Square D QO™ Plug-On Neutral Load Centers also known as Load Centers, Breaker Boxes, Electric Panels

Manufactured February 2020 – January 2022



Indoor Load Center



Outdoor Load Center

Within affected QO Plug-On Neutral Load Centers, the wire binding screw may not be fully tightened to the neutral bar.

**Free inspection and repair for recalled product shall be provided.**

Instructions on how to inspect the load center can be found at <https://se.com/us/qoloadcenter-safetyrecallnotice> For more information contact Schneider Electric Customer Care.

- By phone at 1-888-778-2733; option 2,1,4 from 8AM-5PM EST
- Chat <https://www.se.com/us/en/work/support/customer-care/contact-schneider-electric.jsp>
- Visit: <https://se.com/us/qoloadcenter-safetyrecallnotice>

**Post until October 28, 2022**

In cooperation with the U.S. Consumer Product Safety Commission